Our Ref: DRS/3Mlet1 04 February 2008



Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900 Fax: +44 (0) 1244 681330 Email: info@siracertification.com Web: www.siracertification.com

Mr M Bent 3M Centre Cain Road, Bracknell Berkshire RG12 8HT

Dear Mike,

I have reviewed the details you sent to me and can confirm that your cable joints do not come under ATEX 94/9/EC because they are part of the cabling system. Cables are not certified for use in hazardous areas but the requirements for suitable cables and joints are dealt with in EN IEC 60079-14 - Installation in hazardous areas.

Effectively this means they are covered under good practice under the DSEAR (ATEX 137) regulations.

The joints would only be considered under the product side if they formed part of a product, rather than the supply cable.

I hope this helps

Best regards David Stubbings

Certification Manager Ex Products