



11KV 33KV CABLE JOINTS & CABLE TERMINATIONS
FURSE EARTHING
www.cablejoints.co.uk
Thorne and Derrick UK
Tel 0044 191 490 1547 Fax 0044 191 477 5371
Tel 0044 117 977 4647 Fax 0044 117 9775582

Heatshrink Joints to suit Low Voltage Cables type Pilc/Swa/Pvc 0.6/3.3kV

- Meets the jointing requirements of BS 6910 part 1
- Unlimited shelf life
- Slim profile
- Allows for immediate backfill
- No messy toxic resins involved
- Suitable for Ocm cable applications



A range of joints are also available for jointing both pilc to xlpe transition and pilc to pilc cables.

These joints offer the same benefits and comprise of similar components to those in the polymeric range, with the addition of breakout boots, core tubes and earthing for the lead sheath on paper cables.

HEATSHRINK JOINTS 3 CORE PILC TO PILC		
PART NUMBER	CABLE RANGE	VOLTAGE
SPAP 16-35-3	16 - 35mm ²	600/1000V
SPAP 50-95-3	50 - 95mm ²	600/1000V
SPAP 120-150-3	120 - 150mm ²	600/1000V

HEATSHRINK JOINTS 4 CORE PILC TO PILC		
PART NUMBER	CABLE RANGE	VOLTAGE
SPAP 16-35-4	16 - 35mm ²	600/1000V
SPAP 50-95-4	50 - 95mm ²	600/1000V
SPAP 120-150-4	120 - 150mm ²	600/1000V
SPAP 185-300-4	185 - 300mm ²	600/1000V

HEATSHRINK TRANSITION JOINTS 4 CORE PILC TO XLPE		
PART NUMBER	CABLE RANGE	VOLTAGE
SPS 386	16 - 35mm ²	600/1000V
SPS 910	50 - 95mm ²	600/1000V
SPS 440	120 - 150mm ²	600/1000V
SPS 350	185 - 300mm ²	600/1000V