


Project: Gripple Hangers
Client: Gripple Ltd
Client's Order No: 3061
Inspection Date:
First: 12/03/2009

Certificate No: COV 0919097
Office: Sheffield
Date: 20/02/2009
Order Status: Complete
Final: 12/03/2009

This certificate is issued to Gripple Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
 Surveyor of Lloyd's Register



Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Result		
No.1 M6 Barrel	7x7 (6/1)	0 -10 kg 0 - 22 lbs	50 kg 100 lbs	96.1 kg 211.4 lbs	99.8 kg 219.56 lbs	102.5 kg 265.1 lbs
No.2 M6 Barrel	7x7 (6/1)	10 - 45 kg 22 - 100 lbs	225 kg 495 lbs	292.2 kg 642.84 lbs	248.6 Kg 546.92 lbs	297.2 Kg 653.84 lbs



CABLE JOINTS, CABLE TERMINATIONS, CABLE GLANDS, CABLE CLEATS
 FEEDER PILLARS, FUSE LINKS, ARC FLASH, CABLE ROLLERS, CUT-OUTS

11KV 33KV CABLE JOINTS & CABLE TERMINATIONS
 FURSE EARTHING
www.cablejoints.co.uk
Thorne and Derrick UK

Tel 0044 191 490 1547 Fax 0044 191 477 5371
 Tel 0044 117 977 4647 Fax 0044 117 9775582