



WWW.CABLEJOINTS.CO.UK  
**THORNE & DERRICK UK**  
 TEL 0044 191 490 1547 FAX 0044 477 5371  
 TEL 0044 117 977 4647 FAX 0044 977 5582  
 WWW.THORNEANDDERRICK.CO.UK

## SAIF: key and information required

### Key

#### Enclosure

- P - Outdoor feeder pillar
- B - Indoor fuseboard
- C - Outdoor fuse cabinet

#### Incoming Connections

- C - Cable connections
- F - Flange mounted

#### Disconnecter / flange position

- C - Incoming centre of unit
- R - Incoming right of unit
- L - Incoming left of unit

### Information required

For enquires or order specification, please include as much of the following information as possible:

#### Format and rating

- Pillar, board or cabinet
- Type 2400, 1600 or 800
- Cable or flange connected
- Central or off-set

#### SAIF ways

- Number of ways
- Future way spaces
- Type 800, 630 or 400

#### Cables

- Size and type
- Glands required

#### Auxiliaries

- Instrument and CTs
- Interior light
- Socket outlet
- Space heater
- Street lighting, etc

#### Circuit breakers

- Incoming and outgoing MCCB's up to 1250A,
- ACB's up 3200A Protection unit

**Notes: Applies to standard units incorporating disconnectors and fuseways only.**

– Outline drawings of individual requirements are available upon request.

– All details and dimensions are for guidance and subject to confirmation at the time of contract.