


**Fig. 13 Code ESI-C1-2T1
Earthing Lead**

To be terminated only with terminations as Fig 14.
 For attachment to earth end and line end clamps as in Figs.4 to 11 inclusive.

Tested to 17.5kA for 2 secs.

Length as required.



ESI/T1

Fig. 14 Code ESI-T1

Compression Termination to suit 150mm² Aluflex.
 Compress to 22.73 A/Fx 76.2mm Bite Length



Operating Socket S9D:ESI-S1

Fig 15 S9D:ESI-S1 Operating Socket


For attachment to glass fibre operating pole as in Fig.17
 and application of line end clamps as in Fig. 4 to 11 inclusive.



Operating Socket CEA/S:ES1-S2

Fig. 16 CEA/S:ES1-S2 Operating Socket

For attachment in glass fibre operating pole as Fig. 11 and application of line
 end clamps as in Figs. 4 to 11 inclusive.



All sizes are in Millimetres