


**Fig. 13 Code ESI-C1-2T1  
Earthing Lead**

To be terminated only with terminations as Fig 14.

For attachment to earth end and line end clamps as in Figs.4 to 11 inclusive.

**Tested to 17.5kA for 2 secs.**

Length as required.



ESI/T1

**Fig. 14 Code ESI-T1**

Compression Termination to suit 150mm<sup>2</sup> Aluflex.

Compress to 22.73 A/Fx 76.2mm Bite Length



Operating Socket S9D:ESI-S1

**Fig 15 S9D:ESI-S1 Operating Socket**


For attachment to glass fibre operating pole as in Fig.17  
and application of line end clamps as in Fig. 4 to 11 inclusive.



Operating Socket CEA/S:ES1-S2

**Fig. 16 CEA/S:ES1-S2 Operating Socket**

For attachment in glass fibre operating pole as Fig. 11 and application of line  
end clamps as in Figs. 4 to 11 inclusive.



**All sizes are in Millimetres**