


## **Enclosure Type** Stainless Steel Size I

Increased Safety Exe **Dual Certified ATEX/IECEX** 



MAXIMUM QUANTITY OF ENTRIES PER FACE										
Thread Size	MI6	M20/O	M20/A	M25	M32					
Quantity	5 #	5 #	3	2	I					

# Serrated Washers/Locknuts with large outside diameters may foul on adjacent glands.

\* Serrated Washers/Locknuts must not foul on aperture wall.

Note: For Cable Entry Positions see page 32.

## **Technical Data**

- Increased Safety Exe. 🐼 II 2 GD Exe II ExtD A21
- SIZE I Certificate No.
- Baseefa 08 ATEX 0208X & IECEx BAS 08.0065X
- ZSIZE I Certificate No. Baseefa 08 ATEX 0207U & IECEx BAS 08.0064U
- Suitable for use in Zone 1, Zone 2, Zone 21 & Zone 22.
- Construction and test standards IEC/EN 60079-0 & IEC/EN 60079-7, IEC/EN 61241-0 & IEC/EN 61241-1.
- IP66 ingress protection to IEC/EN 60529.
- DTS01 deluge protection witnessed by EECS.
- Operating temperature range -60°C to +80°C.
- Temperature Class and Ambient T6 40°C. Optional T5 with ambients up to 65°C.
- Assembly instruction data sheet No. A.I. 266. For SIZE 1.
- Assembly instruction data sheet No. A.I. 267. For ZSIZEI.
- 210mm deep option available.
- Alternative Certification Options Available.
  - Exe II.
  - C(UL)us AExe II/Exe II.
- CGOST R-Exe IIU.

For full Technical Specification see page 35.

TERMINAL CAPACITY DATA											
Terminal Type	Condu	Conductor Size (mm²)		Max. Physical Terminal Content		Reduced Terminal Content at Max.Terminal Amps					
	Min.	Max.	Volts	Terminal Quantity	Amps	Terminal Quantity	Amps				
WDU 2.5	0.5	2.5	550	30	13	18	17				
WDU 4	0.5	4	690	25	17	16	22				
WDU 6	0.5	6	550	19	24	13	29				
WDU I0	1.5	10	550	15	34	П	40				
WDU 16	1.5	16	690	13	45	9	53				
WDU 35	2.5	35	690	9	75	6	87				

Notes: For Junction Box Wattage Factor & Combined Terminal Resistance see pages 37 - 39.

The box is supplied with an integral internal/external earth stud assembly.

The terminals listed are restricted to a minimum operating temperature of -50°C.





www.cablejoints.co.uk Thorne and Derrick UK Tel 0044 191 490 1547 Fax 0044 191 477 5371 Tel 0044 117 977 4647 Fax 0044 117 9775582

