



**CHECK THE ABSENCE OF VOLTAGE ON THE CAPACITIVE  
TERMINALS OF PLUG-IN M.V BUSHINGS  
CONFORM TO EDF / SPS N° 42 SPECIFICATION**

- Tension range : . 10 / 36 kV
- Threshold release : . < à 400 V
- End piece : . K type
- Signal : .Signal via beeping and bright red flashing of electro-luminescent diodes
- Test : .Self integrated
- .Power supply : .4 1.5V, R6 batteries
- .Tester in rigid case with batteries